

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Action	location
JE 01	2/6/2024 06:32	2/13/2024 10:52	70286737001	Lead	<1.0	5	ug/L		
JE 02	2/6/2024 06:34	2/13/2024 10:58	70286737002	Lead	<1.0	5	ug/L		
JE 03	2/6/2024 06:34	2/13/2024 11:03	70286737003	Lead	22.5	5	ug/L	Posted Sign	rm 104
JE 04	2/6/2024 06:36	2/13/2024 11:08	70286737004	Lead	2.0	5	ug/L		
JE 05	2/6/2024 06:39	2/13/2024 11:09	70286737005	Lead	12.0	5	ug/L	taken out of service	rm 105 drinking fountain
JE 06	2/6/2024 06:41	2/13/2024 11:11	70286737006	Lead	7.6	5	ug/L	Posted Sign	rm 106 sink
JE 07	2/6/2024 06:41	2/13/2024 11:13	70286737007	Lead	3.4	5	ug/L		
JE 08	2/6/2024 06:44	2/13/2024 11:14	70286737008	Lead	3.6	5	ug/L		
JE 09	2/6/2024 06:44	2/13/2024 11:16	70286737009	Lead	13.3	5	ug/L	taken out of service	rm 116 drinking fountain
JE 10	2/6/2024 06:46	2/13/2024 11:17	70286737010	Lead	3.2	5	ug/L		
JE 11	2/6/2024 06:46	2/13/2024 11:19	70286737011	Lead	1.5	5	ug/L		
JE 12	2/6/2024 06:48	2/13/2024 11:20	70286737012	Lead	8.1	5	ug/L	Posted Sign	rm 117 classroom sink
JE 13	2/6/2024 06:48	2/13/2024 11:22	70286737013	Lead	3.2	5	ug/L		
JE 14	2/6/2024 06:49	2/13/2024 11:27	70286737014	Lead	3.2	5	ug/L		
JE 16	2/6/2024 06:32	2/13/2024 11:28	70286737015	Lead	7.4	5	ug/L	Posted Sign	rm 122 classroom sink
JE 17	2/6/2024 06:30	2/13/2024 11:30	70286737016	Lead	<1.0	5	ug/L		
JE 18	2/6/2024 06:31	2/13/2024 11:31	70286737017	Lead	<1.0	5	ug/L		
JE 19	2/6/2024 06:21	2/13/2024 11:33	70286737018	Lead	18.3	5	ug/L	Posted Sign	rm 152 classrom sink
JE 20	2/6/2024 06:22	2/13/2024 11:35	70286737019	Lead	13.2	5	ug/L	Posted Sign	rm 154 classroom sink
JE 21	2/6/2024 06:25	2/13/2024 11:36	70286737020	Lead	<1.0	5	ug/L		
JE 22	2/6/2024 06:29	2/13/2024 11:41	70286737021	Lead	<1.0	5	ug/L		
JE 23	2/6/2024 06:19	2/13/2024 11:49	70286737022	Lead	3.7	5	ug/L		
JE 24	2/6/2024 06:20	2/13/2024 11:54	70286737023	Lead	6.0	5	ug/L	Posted Sign	art room classroom sink 2
JE 25	2/6/2024 06:20	2/13/2024 11:55	70286737024	Lead	3.8	5	ug/L		
JE 26	2/6/2024 06:16	2/13/2024 11:57	70286737025	Lead	6.8	5	ug/L	Posted Sign	room 140 classroom sink
JE 27	2/6/2024 06:13	2/13/2024 11:58	70286737026	Lead	5.4	5	ug/L	Posted Sign	room 138 classroom sink
JE 28	2/6/2024 06:11	2/13/2024 12:00	70286737027	Lead	<1.0	5	ug/L		
JE 29	2/6/2024 06:14	2/13/2024 12:05	70286737028	Lead	<1.0	5	ug/L		
JE 30	2/6/2024 06:09	2/13/2024 12:06	70286737029	Lead	5.6	5	ug/L	Posted Sign	room 135 classroom sink
JE 31	2/6/2024 06:07	2/13/2024 12:08	70286737030	Lead	3.7	5	ug/L		
JE 32	2/6/2024 06:06	2/13/2024 12:09	70286737031	Lead	19.8	5	ug/L	Posted Sign	room 139 classroom sink
JE 33	2/6/2024 06:17	2/13/2024 12:11	70286737032	Lead	<1.0	5	ug/L		
JE 34	2/6/2024 06:18	2/13/2024 12:12	70286737033	Lead	<1.0	5	ug/L		
JE 35	2/6/2024 06:57	2/13/2024 12:14	70286737034	Lead	<1.0	5	ug/L		
JE 36	2/6/2024 06:57	2/13/2024 12:16	70286737035	Lead	8.1	5	ug/L	Posted Sign	room 205 classroom sink
JE 37	2/6/2024 06:59	2/13/2024 12:17	70286737036	Lead	6.7	5	ug/L	Posted Sign	room 207 classroom sink
JE 38	2/6/2024 06:59	2/13/2024 12:19	70286737037	Lead	7.6	5	ug/L	taken out of service	room 207 drinking fountain
JE 39	2/6/2024 07:00	2/13/2024 12:23	70286737038	Lead	5.4	5	ug/L	Posted Sign	room 209 classroom sink
JE 40	2/6/2024 07:01	2/13/2024 12:25	70286737039	Lead	6.4	5	ug/L	Posted Sign	room 152 classroom sink
JE 41	2/6/2024 07:02	2/13/2024 12:27	70286737040	Lead	5.5	5	ug/L	Posted Sign	room 154 classroom sink
JE 42	2/6/2024 07:02	2/13/2024 12:31	70286737041	Lead	3.9	5	ug/L		
JE 43	2/6/2024 07:05	2/13/2024 12:36	70286737042	Lead	10.4	5	ug/L	Posted Sign	room 210 classroom sink
JE 44	2/6/2024 07:06	2/13/2024 12:44	70286737043	Lead	15.7	5	ug/L	taken out of service	room 210 drinking fountain
JE 45	2/6/2024 07:07	2/13/2024 12:46	70286737044	Lead	6.1	5	ug/L	Posted Sign	room 208 classroom sink
JE 46	2/6/2024 07:07	2/13/2024 12:47	70286737045	Lead	1.7	5	ug/L		
JE 47	2/6/2024 07:08	2/13/2024 12:49	70286737046	Lead	5.0	5	ug/L		
JE 48	2/6/2024 07:09	2/13/2024 12:50	70286737047	Lead	4.1	5	ug/L		
JE 49	2/6/2024 06:55	2/13/2024 12:52	70286737048	Lead	4.2	5	ug/L		
JE 50	2/6/2024 06:55	2/13/2024 12:53	70286737049	Lead	2.9	5	ug/L		
JE 51	2/6/2024 07:04	2/13/2024 12:55	70286737050	Lead	27.4	5	ug/L	Posted Sign	room 213 classroom sink
JE 52	2/6/2024 07:04	2/13/2024 12:57	70286737051	Lead	3.6	5	ug/L		
JE 53	2/6/2024 06:24	2/13/2024 13:01	70286737052	Lead	14.6	5	ug/L	Posted Sign	room 153 sink
JE 54	2/6/2024 06:27	2/13/2024 13:03	70286737053	Lead	4.5	5	ug/L		
JE 55	2/6/2024 06:38	2/13/2024 13:04	70286737054	Lead	<1.0	5	ug/L		
JE 56	2/6/2024 06:51	2/13/2024 13:06	70286737055	Lead	<1.0	5	ug/L		
JE 57	2/6/2024 06:52	2/13/2024 13:08	70286737056	Lead	2.2	5	ug/L		

NYSDOH Action Level for Lead In Schools of 5 ppb